

Symmetra PX Battery Enclosure


10-80 kW

Installation Manual



Symmetra® PX 10-80kW Battery Enclosure

Installation Manual





Contents

IMPO	PRTANT SAFETY INSTRUCTIONS	1
	SAVE THESE INSTRUCTIONS	
	Symbols used in this guide 1	
	ON, OFF & STAND-BY switch symbols 2	
	Operating conditions	
	Battery Safety	
	Total power OFF procedure	
	Electrical Requirements and Specifications 5	
	Recommended Wiring for 208 V installations 5	
	Recommended Wiring for 400 V installations 5	
Instal	llation Procedures	6
	Bottom wiring	
	Side-panel wiring (steps 1-6)	
	Side-panel wiring (steps 7-13) 8	
	Side-panel wiring (steps 14-16) 9	
	DC Power input/output wiring10	
	Interconnect schematic	
	Routing of communication cables (steps 1-9) 12	
Powe	er Wiring Verification on Site	4
Life S	Support Policy/Warranty 1	5
	Life support policy	
	Examples of life-support devices	
	Factory Warranty	

i

IMPORTANT SAFETY INSTRUCTIONS

SAVE THESE INSTRUCTIONS

This guide contains important instructions that should be followed when handling the UPS, Battery Enclosures, and Batteries.

Symbols used in this guide



WARNING!

Risk of Electric Shock.



CAUTION!

Read this information.



Indicates important information.



Indicates a heavy load that should not be lifted without assistance.



Indicates that more information is available on this subject in a different section of this manual.



Indicates that more information is available on the same subject in a different manual.

		AA.	
<18 kg.	18 - 32 kg.	32 - 54 kg.	>54 kg.
< 40 lb.	40 - 70 lb.	70 - 120 lb	120 lb.>

ON, OFF & STAND-BY switch symbols

Indicates the ON position for a switch or breaker.

Indicates the OFF position for a switch or breaker.

Indicates the STAND-BY position for a switch or breaker.

Operating conditions

Install the Battery Enclosure in an indoor, controlled environment				
Temperature Range: 32°-104°F 0°-40°C	Keep ventilated front-to-rear airflow	Relative humidity: < 95 % non-condensing	No conductive dust or corrosive fumes	Elevation: 0-10,000 ft. 0-3,000 m

Battery Safety



WARNING!

- Risk of Electrical Shock and Energy Hazard, 96 V, 7.2 Ah battery.
- All electrical power and power control wiring must be installed by APC-trained personnel or a qualified electrician, and must comply with local and national regulations.
- The UPS and Battery Enclosure contain an internal energy source. Hazardous voltage may be present even when disconnected from the power source. Follow Total Power Off Procedure to completely de-energize the system.
- Battery Units do not contain serviceable parts. Do not open.
- To replace a Battery Unit, use only the same APC Battery Unit, model SYBTU1.
- Remove all conductive jewelry such as chains, watches, and rings before handling the Battery Units.
- Use tools with insulated handles.
- Wear rubber gloves and boots.
- Do not lay tools or metal parts on top of batteries.
- Do not dispose of batteries in a fire, as they may explode. Do not mutilate batteries, as released electrolyte is harmful to the skin and eyes, and may be toxic.
- For configurations including customer-supplied external batteries, refer to manufacturer's battery installation and maintenance instructions.



CAUTION!

Only qualified, APC-trained personnel should replace batteries. When replacing batteries, replace with same number and type as installed.




Each Battery Unit weighs 50 lbs./23 kg. Two people to replace Battery Unit.

Total power OFF procedure



WARNING!


Before electrical installation/module handling begins, verify that all systems are in the Total Power Off mode by following this procedure.





CAUTION!

To ensure solid stability, do not pull Battery Units out beyond the red disconnect line unless completely removing them from the enclosure.



Electrical Requirements and Specifications

WARNING!



All electrical power and power control wiring must be installed by a qualified electrician, and must comply with local and national regulations for maximum UPS power rating.

Smmetra PX Battery Enclosure 10 - 80 kW			
Battery Voltage (nominal) +/- 192 V			
Battery Current (at full load)	223 A at +/- 192 V		
Max. Current (at end of discharge)	266 A at +/- 160 V		



If external batteries are customer-supplied, refer to product-specific data.



Power and ground wires provided are for internal side-panel wiring only. They are NOT for use in external conduits / external wiring.

Recommended Wiring for 208 V installations

- 1. DC power Input/Output; 2/0 AWG (supplied) for adjacent enclosures; 4/0 AWG (not supplied) for separated enclosures.
- 2. Use Molux lug type (detailed below) or equivalent and crimp to manufacturer's specifications.

Cable Size (AWG)	Terminal Bolt	Cable Lug Type
2/0	M10	19221-0244
4/0	M10	19221-0250

Recommended Wiring for 400 V installations

- 1. DC power Input/Output: 120 mm^2 PVC power cables isolated to withstand a maximum ambient temperature of 40° C.
- 2. External PE cable: 70 mm².

Installation Procedures



For side-panel wiring option, see Side-panel wiring section.




Make sure the unit is in its location of use before wiring begins.



For communication with the UPS and other Battery Enclosures, use standard CAT 5 data cable. Maximum length: 165 ft. (50 m) for entire loop.

Bottom wiring



Side-panel wiring (steps 1-6)



Rearrange side panels so all inner panels have adjacent wiring holes, and outer panels are solid.




Remove rear hole covers before mounting inner panels.



Reconnect all panel ground wires. Arrange hardware as shown in step 5. Torque value: 80 lb-in (9 Nm).




Lock all panels.






If required, adjust Battery Enclosures for hole alignment using stabilizing feet.

Side-panel wiring (steps 7-13)



Side-panel wiring (steps 14-16)



DC Power input/output wiring


Power terminal lug diameter: 10 mm.

Torque value: 87 in-lb (10 Nm).




Power and ground wires provided are for internal side-panel wiring only. They are NOT for use in external conduit.

- Connect Battery Enclosure DC output to UPS DC input. Connect Battery Enclosures to UPS ground stud.
- If applicable: Connect 2nd Battery Enclosure DC output to 1st Battery Enclosure DC input. Connect ground wire as shown. Continue this string up to 4 Battery Enclosures.



Interconnect schematic



Routing of communication cables (steps 1-9)



WARNING!

Ensure Total Power Off (see Total Power Off procedure section).



If side-panel access is obstructed, access from the rear


The instructions below are applicable for wiring through rear and bottom of the Battery Enclosure.




If cable length is inadequate, a longer CAT 5 cable, or couplers, can be used (not supplied). Max. length: 165 ft/50 m for entire loop.



Open right side panel to gain access to the communication cables.



Reinstall and lock all side-panels.



Power Wiring Verification on Site

This section should be completed by the electrician when the wiring has been completed.				
Installed at (Company):				
Customer Contact Name:				
Telephone:				
Wire size and type (if external):				
Do not install battery units in the Battery Enclosure. Batteries will be installed by APC during the Start-Up procedure.				
Use following procedure to verify that the Battery Enclosures have been wired properly.				
Ensure all power wiring is torqued to 87 in-lb (10 Nm).				
Check polarity between connections.				
☐ Reinstall all wiring access panels.				
If a problem occurs, call APC Customer Support (rear cover):				
Successful wiring completed by (name of electrician):				
Name: Date:				
Company				

Life Support Policy/Warranty

Life support policy

American Power Conversion Corporation (APC), its affiliates and subsidiaries world-wide, do not recommend the use of any of their products in life support applications where failure or malfunction of the APC product can be reasonably expected to cause failure of the life support device or to significantly affect its safety or effectiveness. APC does not permit the use of any of its products in direct patient care. APC will not knowingly sell its products for use in such applications unless the life support system or direct patient care device is part of a whole facility/building into which the UPS is integrated and unless APC receives in writing assurances satisfactory to APC that:

- (a) the UPS system will be configured in a manner that will provide N+1 power redundancy to the critical load,
- (b) the end-user assumes all risks and signs the APC System Configurations and Use Form, and
- (c) the customer and operators of the APC UPS system agree to indemnify and hold APC and its affiliates and subsidiaries harmless for any and all claims arising out of the system's use in such applications.

Examples of life-support devices

The term *life-support device* includes but is not limited to neonatal oxygen analyzers, nerve stimulators (whether used for anesthesia, pain relief, or other purposes), autotransfusion devices, blood pumps, defibrillators, arrhythmia detectors and alarms, pacemakers, hemodialysis systems, peritoneal dialysis systems, neonatal ventilator incubators, ventilators (for adults and infants), anesthesia ventilators, infusion pumps, and any other devices designated as "critical" by the U.S. FDA.

Hospital-grade wiring devices and leakage current protection may be ordered as options on many APC UPS systems. APC does not claim that units with these modifications are certified or listed as hospital-grade by APC or any other organization. Therefore these units do not meet the requirements for use in direct patient care.

Factory Warranty

APC warrants that the unit, when properly installed and commissioned by APC or APC authorized service personnel, shall be free from defects in materials and workmanship for a period of (1) year from the date of installation or maximum 18 months after manufacturing. In the event that the unit fails to meet the foregoing warranty, APC shall for a period of one (1) year repair or replace any defective parts, without charge for on-site labor and travel if trained & authorized APC personnel has conducted start-up of the unit.

An APC Start-Up Service must be performed/completed by APC or by service personnel authorized by APC. If not, the on-site factory warranty will be voided and replacement of defective parts only will be covered. APC shall have no liability and no obligation to repair the installed unit if non-authorized APC personnel performed the start-up and such start-up caused the unit to be defective.

APC shall not be liable under the warranty if its testing and examination disclose that the alleged defect in the product does not exist or was caused by purchaser's or any third person's misuse, negligence, improper installation or testing, unauthorized attempts to repair or modify, or any other cause beyond the range of the intended use, or by accident, fire, lightning or other hazard.

There are no warranties, expressed or implied, by operation of law or otherwise, of products sold, serviced or furnished under this agreement or in connection herewithin. APC disclaims all implied warranties of merchantability, satisfaction and fitness for a particular purpose. APC's express warranties will not be enlarged, diminished, or affected by and no obligation or liability will arise out of, APC rendering of technical or other advice or service in connection with the products. The foregoing warranties and remedies are exclusive and in lieu of all other warranties and remedies. The warranties set forth above, constitute APC's sole liability and purchaser's exclusive remedy for any breach of such warranties. APC's warranties apply only to purchaser and are not extended to any third parties.

In no event shall APC, its officers, directors, affiliates or employees be liable for any form of indirect, special, consequential or punitive damages, arising out of the use, service or installation, of the products, whether such damages arise in contract or tort, irrespective of fault, negligence or strict liability or whether APC has been advised in advance of the possibility of such damages.



APC Worldwide Customer Support

Customer support for this or any other APC product is available at no charge in any of the following ways:

- Visit the APC Web site to find answers to frequently asked questions (FAQs), to access documents in the APC Knowledge Base, and to submit customer support requests.
 - www.apc.com (Corporate Headquarters)
 Connect to localized APC Web sites for specific countries, each of which provides customer support information.
 - www.apc.com/support/
 Global support with FAQs, knowledge base, and e-support.
- Contact an APC Customer Support center by telephone or e-mail.
 - Regional centers:

Australia	1800 652 725	Malaysia	1800 80 1030
Austria	0800 999670	Netherlands	0800 0232509
Belgium	0800 40677	New Zealand	0800 333 373
China	+86 800 810 0160	Norway	800 10436
Czech Republic	800 102063	Poland	0801 345917
Denmark	80 884953	Portugal	800 853182
Finland	0800 115308	Russia	8800 2002722
France	0805 110053	Singapore	+65 638 96 823
Germany	0800 1010067	Slovak Republic	0800 172063
Greece	00800 125924	South Africa	0861 272877
Hong Kong	+852 2834 5001	Spain	800 099340
Hungary	0640 200262	Sweden	0200 895283
India	080 573 7497	Switzerland	0800 111469
Ireland	1890 272877	Turkey	0800 2612135
Israel	1800 9452206	UK	0800 2799254
Italy	800 905821	USA	(1)(800) 800-4272 (toll-free)
Latin America	(1)(401) 789-5735 (USA)	Ukraine	8800 5027220
Luxemburg	800 22091	Fax	+353 91 755275

Local, country-specific centers: go to www.apc.com/support/contact for contact information.

Contact the APC representative or other distributor from whom you purchased your APC product for information on how to obtain local customer support.

Entire contents copyright © 2003 American Power Conversion. All rights reserved. Reproduction in whole or in part without permission is prohibited. APC, the APC logo, and Symmetra are trademarks of American Power Conversion Corporation and may be registered in some jurisdictions. All other trademarks, product names, and corporate names are the property of their respective owners and are used for informational purposes only.

990-1424A 08/2003